



ROGERS STATE UNIVERSITY
1701 W. WILL ROGES BLVD.
CLAREMORE, OK 74017

RE: Addendum No. 4

PROJECT: Request for Bid – Phase 2 Roof Replacement - RFB 2021-03

DATE OF REQUEST FOR BID: January 14th, 2021

DATE OF ADDENDUM ISSUE: February 19th, 2021

THIS SCOPE OF WORK IS HEREBY MADE PART OF THE CONTRACT AS THOUGH IT HAD BEEN INCLUDED ORIGINALLY THEREIN, AND IT SHALL SUPERSEDE ANYTHING CONTAINED IN THE CONTRACT WITH WHICH IT MIGHT CONFLICT.

CLARIFICATIONS:

Item No. 1 – All buildings except for Herrington Hall ad Health Sciences that are having shingles replaced will have ice and water protection applied only at valley, and eaves as specified. Contractor is responsible to verify all measurements and quantities of materials.

Item No. 2 – All new shingle roofs will require the installation of ridge cap shingles.

ADDITIONS:

NO ADDITIONS

CHANGES:

NO CHANGES

END OF ADDENDUM